

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate No:
MEDB000005Y
Revision No:
2

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV GL AS under the authority of the Government of the Kingdom of Norway.

This is to certify:**That the "A" Class divisions, fire integrity**

with type designation(s)

Steel Bulkhead A30 with SeaRox FB 6020/SeaRox FB 6050 or SeaRox FB 6020/ SeaRox FM 6030 ALU


Issued to

**Rockwool International A/S
HEDEHUSENE, Denmark**

is found to comply with the requirements in the following Regulations/Standards:

Regulation **(EU) 2015/559,****Annex A.1, item No. A.1/3.11a and Annex B, Module B in the Directive; SOLAS 74 as amended, Regulation II-2/3.2.5 and IMO 2010 FTP Code**

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2020-09-28.**Issued at **Høvik** on **2017-03-08**DNV GL local station:
Copenhagenfor **DNV GL AS**Approval Engineer:
Fryderyk HogaNotified Body
No.: **0575****Vidar Dolonen**
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment" signed 17 October 2005.

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.



Job Id: **344.1-004873-3**
Certificate No: **MEDB000005Y**
Revision No: **2**

Product description

"Steel Bulkhead A30 with SeaRox FB 6020/SeaRox FB 6050 or SeaRox FB 6020/ SeaRox FM 6030 ALU"
composed of steel bulkhead to be insulated with one of the following variants:

1. SeaRox FB 6020 (density 40 kg/m³) between the stiffeners and SeaRox FB 6050 (density 70 kg/m³) around and upon the stiffeners OR
2. SeaRox FB 6020 (density 40 kg/m³) between the stiffeners and SeaRox FM 6030 ALU (density 50 kg/m³) around and upon the stiffeners.

For variant 1:

Minimal thickness of the insulation on the bulkhead between the stiffeners is 70 mm. Minimal thickness of the insulation around and upon the stiffeners is 30 mm. Insulation density range on the bulkhead between the stiffeners is 40-100 kg/m³ and on the stiffeners 70-100 kg/m³.

For variant 2:

Minimal thickness of the insulation on the bulkhead between the stiffeners is 70 mm. Minimal thickness of the insulation around and upon the stiffeners is 30 mm. Insulation density range on the bulkhead between the stiffeners is 40-100 kg/m³ and on the stiffeners 50-100 kg/m³.

For all variants:

- The insulation is fixed to the bulkhead by means of standard 3 mm pins in combination with 30-38 mm diameter steel clips (spring washers).
- Distance between pins on the stiffeners is maximum 300 mm. Distance between pins on the bulkhead (between stiffeners) is maximum 300 mm.

For further details about pin-settings and design see drawings listed under Type Examination documentation below.

Application/Limitation

Approved for use as a vertical fire retarding division of class A-30.

The insulation materials and adhesives used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

Each product is to be supplied with its manual for installation, use and maintenance.

Type Examination documentation

Test report Nos.:

- PGA10658 dated 4 May 2015
- PGA10731 dated 22 September 2015


Both test reports from DBI (Danish Institute of Fire and Security Technology), Hvidovre, Denmark.

Assessment Report Nos.:

- PHA10628a dated 7 July 2015
- PHA10628b dated 7 July 2015
- PHA10628c dated 7 July 2015
- PHA10628d dated 7 July 2015
- PHA10628e dated 7 July 2015
- PHA10628f dated 11 August 2015

All assessment reports from DBI (Danish Institute of Fire and Security Technology), Hvidovre, Denmark.

Drawing Nos. from 160-1 to 160-5 dated 2 July 2015 and from 170-1 to 170-4 dated 8 July 2016, all from the manufacturer.



Job Id: **344.1-004873-3**
Certificate No: **MEDB000005Y**
Revision No: **2**

Tests carried out

Tested according to IMO 2010 FTP Code part 3.

Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire technical rating, the MED Mark of Conformity and USCG approval number if applicable (see first page).